

Stage 2 Disinfectants and Disinfection Byproducts Rule Reporting Spreadsheet

Water System: DC Water
PWSID: DC0000002
Report Period: 1st Quarter 2018

- Steps: 1. Use data from three previous quarters
 2. Enter sample date and results for current quarter of monitoring in the blue column.
 3. Summarize results for the quarter. The number of samples should include the number of any repeat samples.

Total Trihalomethanes (TTHM)
 Reported as mg/L or ppm

Number of TTHM samples taken per quarter: 12
 Operational Evaluation Levels exceeded (Yes/No): No
 TTHM MCL violations: No

		Three Most Recent Quarters of Sampling Results*			Current Quarter	
Scheduled Sample Month		May 2017	Aug 2017	Nov 2017	Feb 2018	
Actual Sample Date:						
Location ID	Location Name				Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
1H-9	1700 EAST CAPITOL ST NE	0.039	0.076	0.031	0.020	0.037
1H-23	407 8th St. NE	0.038	0.082	0.030	0.020	0.038
2H-1 BKJV	1731 BUNKER HILL RD NE	0.039	0.081	0.035	0.023	0.041
2H-27	3101 Rhode Island Ave, NE	0.037	0.082	0.033	0.020	0.039
3H-4 BKJV	1640 KALMIA RD NW	0.035	0.072	0.033	0.023	0.038
3H-13	120 KENNEDY ST NW	0.033	0.057	0.035	0.022	0.034
4H-8	5608 BROAD BRANCH RD NW	0.031	0.058	0.028	0.021	0.032
A1H-3 BKJV	420 56TH ST NE	0.042	0.080	0.037	0.024	0.041
A1H-8	3125 MARTIN LUTHER KING AVE SE	0.039	0.071	0.029	0.020	0.035
L-24 DBPR	1350 49TH ST NE	0.044	0.082	0.035	0.026	0.042
L-4	550 WATER ST SW	0.032	0.062	0.031	0.022	0.034
L-12	5000 OVERLOOK AVE SW	0.038	0.067	0.031	0.022	0.036
						If TTHM OEL is > 0.080, perform Operational Evaluation.
						If TTHM LRAA is > 0.080, MCL violation occurred.

Five Haloacetic Acids (HAA5)
 Reported as mg/L or ppm

Number of HAA5 samples taken per quarter: 12
 Operational Evaluation Levels exceeded (Yes/No): No
 HAA5 MCL violations: No

		Three Most Recent Quarters of Sampling Results*			Current Quarter	
Scheduled Sample Month		May 2017	Aug 2017	Nov 2017	Feb 2018	
Actual Sample Date:						
Location ID	Location Name				Operational Evaluation Level (OEL)	Locational Running Annual Average (LRAA)
1H-9	1700 EAST CAPITOL ST NE	0.030	0.047	0.028	0.021	0.029
1H-23	407 8th St. NE	0.027	0.049	0.027	0.018	0.028
2H-1 BKJV	1731 BUNKER HILL RD NE	0.030	0.037	0.015	0.020	0.023
2H-27	3101 Rhode Island Ave, NE	0.026	0.048	0.032	0.018	0.029
3H-4 BKJV	1640 KALMIA RD NW	0.028	0.012	0.028	0.019	0.019
3H-13	120 KENNEDY ST NW	0.027	0.042	0.035	0.023	0.031
4H-8	5608 BROAD BRANCH RD NW	0.025	0.041	0.025	0.021	0.027
A1H-3 BKJV	420 56TH ST NE	0.031	0.041	0.018	0.019	0.024
A1H-8	3125 MARTIN LUTHER KING AVE SE	0.028	0.043	0.027	0.019	0.027
L-24 DBPR	1350 49TH ST NE	0.032	0.016	0.008	0.020	0.016
L-4	550 WATER ST SW	0.024	0.043	0.029	0.019	0.028
L-12	5000 OVERLOOK AVE SW	0.028	0.044	0.028	0.018	0.027
						If HAA5 OEL is > 0.060, perform Operational Evaluation.
						If HAA5 LRAA is > 0.060, MCL violation occurred.